


FLO GUARD TEE	
SCHEDULE 40 PVC X	SCHEDULE 40 PVC
SCHEDULE 40 PVC X	SCHEDULE 40 CLEAR
SCHEDULE 40 CLEAR X	SCHEDULE 40 CLEAR

PIPE SIZE	DIMENSIONS	
	A	B
1/2 X 2	11.396	5.698
3/4 X 2	11.396	5.698
3/4 X 3	14.45	7.225
1 X 3	14.45	7.225
1 1/2 X 4	16.82	8.41
2 X 4	16.82	8.41


FLO SAFE, INC.		
CONTAINMENT FITTINGS		
TEE		
DATE	BY	DWG. NO.
1/7/02	RL	00002001



FLO GUARD TEE	
SCHEDULE 80 PVC X	SCHEDULE 40 PVC
SCHEDULE 80 CPVC X	SCHEDULE 40 PVC
SCHEDULE 80 PVC X	SCHEDULE 40 CLEAR
SCHEDULE 80 CPVC X	SCHEDULE 40 CLEAR

PIPE SIZE	DIMENSIONS	
	A	B
1/2 X 2	11.396	5.698
3/4 X 2	11.396	5.698
3/4 X 3	14.45	7.225
1 X 3	14.45	7.225
1 1/2 X 4	16.82	8.41
2 X 4	16.82	8.41

FLO SAFE, INC.		
CONTAINMENT FITTINGS		
TEE		
DATE	BY	DWG. NO.
1/7/02	RL	00002002



FLO GUARD TEE

SCHEDULE 80 PVC X SCHEDULE 80 PVC
 SCHEDULE 80 CPVC X SCHEDULE 80 PVC
 SCHEDULE 80 CPVC X SCHEDULE 80 CPVC

PIPE SIZE	DIMENSIONS	
	A	B
1/2 X 2	11	5.5
3/4 X 2	11	5.5
3/4 X 3	14	7
1 X 3	14	7
1 1/2 X 4	16.25	8.125
2 X 4	16.25	8.125

FLO SAFE, INC.


CONTAINMENT FITTINGS

TEE

DATE 1/7/02	BY RL	DWG. NO. 00002003
-------------	-------	-------------------

FLO GUARD P-TRAP

SCHEDULE 40 PVC X SCHEDULE 40 PVC
 SCHEDULE 40 PVC X SCHEDULE 40 CLEAR
 SCHEDULE 40 CLEAR X SCHEDULE 40 CLEAR



SCHEDULE 40 PVC X SCHEDULE 40 PVC

PIPE SIZE	DIMENSIONS				
	A	W	X	B	Z
3 X 6	3.5	14.875	6.969	14.875	1.969
4 X 8	4.438	18.625	8.5	18.625	2.313
6 X 10	5	22.375	10.844	22.375	3.5
8 X 12	6.125	26.438	12.813	26.438	4.5
10 X 14	7	47.5	18	47.5	5.75
12 X 16	8	54.125	21	54.125	6.688

SCHEDULE 40 PVC X SCHEDULE 40 CLEAR

SCHEDULE 40 CLEAR X SCHEDULE 40 CLEAR

PIPE SIZE	DIMENSIONS				
	A	W	X	B	Z
3 X 6	3.485	15.54	7.27	15.54	1.75
4 X 8	N/A	N/A	N/A	N/A	N/A
6 X 10	N/A	N/A	N/A	N/A	N/A
8 X 12	N/A	N/A	N/A	N/A	N/A
10 X 14	N/A	N/A	N/A	N/A	N/A
12 X 16	N/A	N/A	N/A	N/A	N/A

FLO SAFE, INC.


CONTAINMENT FITTINGS

P-TRAP

DATE	1/7/02	BY	RL	DWG. NO.	00002004
------	--------	----	----	----------	----------

FLO GUARD P-TRAP

SCHEDULE 80 PVC X SCHEDULE 40 PVC
 SCHEDULE 80 CPVC X SCHEDULE 40 PVC
 SCHEDULE 80 PVC X SCHEDULE 40 CLEAR
 SCHEDULE 80 CPVC X SCHEDULE 40 CLEAR



**SCHEDULE 80 PVC X SCHEDULE 40 PVC
 SCHEDULE 80 CPVC X SCHEDULE 40 PVC**

PIPE SIZE	DIMENSIONS				
	A	W	X	B	Z
3 X 6	3.5	14.875	6.969	14.875	2.094
4 X 8	4.438	18.625	8.5	18.625	2.406
6 X 10	5	22.375	10.844	22.375	3.75
8 X 12	6.125	26.438	12.813	26.438	4.75
10 X 14	7	47.5	18	47.5	5.813
12 X 16	8	54.125	21	54.125	6.75

**SCHEDULE 80 PVC X SCHEDULE 40 CLEAR
 SCHEDULE 80 CPVC X SCHEDULE 40 CLEAR**

PIPE SIZE	DIMENSIONS				
	A	W	X	B	Z
3 X 6	3.485	15.54	7.27	15.54	2.094
4 X 8	N/A	N/A	N/A	N/A	N/A
6 X 10	N/A	N/A	N/A	N/A	N/A
8 X 12	N/A	N/A	N/A	N/A	N/A
10 X 14	N/A	N/A	N/A	N/A	N/A
12 X 16	N/A	N/A	N/A	N/A	N/A

FLO SAFE, INC.


CONTAINMENT FITTINGS

P-TRAP

DATE	1/7/02	BY	RL	DWG. NO.	00002005
------	--------	----	----	----------	----------

FLO GUARD P-TRAP

SCHEDULE 80 PVC X SCHEDULE 80 PVC
 SCHEDULE 80 CPVC X SCHEDULE 80 PVC
 SCHEDULE 80 CPVC X SCHEDULE 80 CPVC



**SCHEDULE 80 PVC X SCHEDULE 80 PVC
 SCHEDULE 80 CPVC X SCHEDULE 80 PVC**

PIPE SIZE	DIMENSIONS				
	A	W	X	B	Z
3 X 6	3.125	14.75	6.875	14.75	2.469
4 X 8	4	18.5	8.75	18.5	2.781
6 X 10	5.563	22.75	11.375	23.75	4.125
8 X 12	6.625	27.75	13.375	27.75	5.125
10 X 14	7.125	48.75	23.875	48.75	6.188
12 X 16	8	54.75	26.875	54.75	7.125

SCHEDULE 80 CPVC X SCHEDULE 80 CPVC

PIPE SIZE	DIMENSIONS				
	A	W	X	B	Z
3 X 6	3.125	14.75	6.875	14.75	2.469
4 X 8	4	18.5	8.75	18.5	2.781
6 X 10	5.563	22.75	11.375	23.75	4.125
8 X 12	6.625	27.75	13.375	27.75	5.125
10 X 14	N/A	N/A	N/A	N/A	N/A
12 X 16	N/A	N/A	N/A	N/A	N/A

FLO SAFE, INC.

CONTAINMENT FITTINGS

P-TRAP

DATE	1/7/02	BY	RL	DWG. NO.	00002006
------	--------	----	----	----------	----------

FLO GUARD LATERAL WYE


SCHEDULE 40 PVC X SCHEDULE 40 PVC
 SCHEDULE 40 PVC X SCHEDULE 40 CLEAR
 SCHEDULE 40 CLEAR X SCHEDULE 40 CLEAR

**SCHEDULE 40 PVC X SCHEDULE 40 PVC
 SCHEDULE 40 PVC X SCHEDULE 40 CLEAR**

PIPE SIZE	DIMENSIONS		
	A	B	C
2 X 4	26	22	22
3 X 6	30	24	24
4 X 8	34	26	26
6 X 10	38	28	28
8 X 12	42	30	30
10 X 14	44	32	32
12 X 16	48	34	34

SCHEDULE 40 CLEAR X SCHEDULE 40 CLEAR

PIPE SIZE	DIMENSIONS		
	A	B	C
2 X 4	26	22	22
3 X 6	30	24	24
4 X 8	N/A	N/A	N/A
6 X 10	N/A	N/A	N/A
8 X 12	N/A	N/A	N/A
10 X 14	N/A	N/A	N/A
12 X 16	N/A	N/A	N/A



FLO SAFE, INC.

CONTAINMENT FITTINGS

LATERAL WYE

DATE 1/7/02	BY RL	DWG. NO. 00002007
----------------	----------	----------------------

FLO GUARD LATERAL WYE


SCHEDULE 80 PVC X SCHEDULE 40 PVC
 SCHEDULE 80 CPVC X SCHEDULE 40 PVC
 SCHEDULE 80 PVC X SCHEDULE 40 CLEAR
 SCHEDULE 80 CPVC X SCHEDULE 40 CLEAR

SCHEDULE 80 PVC X SCHEDULE 40 PVC
SCHEDULE 80 CPVC X SCHEDULE 40 PVC

PIPE SIZE	DIMENSIONS		
	A	B	C
2 X 4	26	22	22
3 X 6	30	24	24
4 X 8	34	26	26
6 X 10	38	28	28
8 X 12	42	30	30
10 X 14	44	32	32
12 X 16	48	34	34

SCHEDULE 80 PVC X SCHEDULE 40 CLEAR
SCHEDULE 40 CPVC X SCHEDULE 40 CLEAR

PIPE SIZE	DIMENSIONS		
	A	B	C
2 X 4	26	22	22
3 X 6	30	24	24
4 X 8	N/A	N/A	N/A
6 X 10	N/A	N/A	N/A
8 X 12	N/A	N/A	N/A
10 X 14	N/A	N/A	N/A
12 X 16	N/A	N/A	N/A



FLO SAFE, INC.

CONTAINMENT FITTINGS

LATERAL WYE

DATE 1/7/02	BY RL	DWG. NO. 00002008
----------------	----------	----------------------

FLO GUARD LATERAL WYE


SCHEDULE 80 PVC X SCHEDULE 80 PVC
 SCHEDULE 80 CPVC X SCHEDULE 80 PVC
 SCHEDULE 80 CPVC X SCHEDULE 80 CPVC

**SCHEDULE 80 PVC X SCHEDULE 80 PVC
 SCHEDULE 80 CPVC X SCHEDULE 80 PVC**

PIPE SIZE	DIMENSIONS		
	A	B	C
2 X 4	26	22	22
3 X 6	30	24	24
4 X 8	34	26	26
6 X 10	38	28	28
8 X 12	42	30	30
10 X 14	44	32	32
12 X 16	48	34	34

SCHEDULE 80 CPVC X SCHEDULE 80 CPVC

PIPE SIZE	DIMENSIONS		
	A	B	C
2 X 4	26	22	22
3 X 6	30	24	24
4 X 8	34	26	26
6 X 10	38	28	28
8 X 12	42	30	30
10 X 14	N/A	N/A	N/A
12 X 16	N/A	N/A	N/A



FLO SAFE, INC.

CONTAINMENT FITTINGS

LATERAL WYE

DATE 1/7/02	BY RL	DWG. NO. 00002009
----------------	----------	----------------------

FLO GUARD END SEAL


SCHEDULE 40 PVC X SCHEDULE 40 PVC
 SCHEDULE 40 PVC X SCHEDULE 40 CLEAR
 SCHEDULE 40 CLEAR X SCHEDULE 40 CLEAR

SCHEDULE 40 PVC X SCHEDULE 40 PVC

PIPE SIZE	DIMENSIONS	
	A	B
1/2 X 2	8.97	5.125
3/4 X 2	8.97	5.125
3/4 X 3	10.805	6.125
1 X 3	10.805	6.125
1 1/2 X 4	12.67	7
2 X 4	12.67	7
3 X 6	16.82	10.42
4 X 8	21.125	11.875
6 X 10	25.625	13.375
8 X 12	30.25	15.75
10 X 14	34.25	17.75
12 X 16	38.5	19.5

**SCHEDULE 40 PVC X SCHEDULE 40 CLEAR
 SCHEDULE 40 CLEAR X SCHEDULE 40 CLEAR**

PIPE SIZE	DIMENSIONS	
	A	B
1/2 X 2	8.97	5.125
3/4 X 2	8.97	5.125
3/4 X 3	10.805	6.125
1 X 3	10.805	6.125
1 1/2 X 4	12.67	7
2 X 4	12.67	7
3 X 6	16.82	10.42
4 X 8	N/A	N/A
6 X 10	N/A	N/A
8 X 12	N/A	N/A
10 X 14	N/A	N/A
12 X 16	N/A	N/A



FLO SAFE, INC.

CONTAINMENT FITTINGS

END SEAL

DATE	1/7/02	BY	RL	DWG. NO.	00002010
------	--------	----	----	----------	----------

FLO GUARD END SEAL


SCHEDULE 80 PVC X SCHEDULE 40 PVC
 SCHEDULE 80 CPVC X SCHEDULE 40 PVC
 SCHEDULE 80 PVC X SCHEDULE 40 CLEAR
 SCHEDULE 80 CPVC X SCHEDULE 40 CLEAR

SCHEDULE 80 PVC X SCHEDULE 40 PVC
SCHEDULE 80 CPVC X SCHEDULE 40 PVC

PIPE SIZE	DIMENSIONS	
	A	B
1/2 X 2	8.97	5.125
3/4 X 2	8.97	5.125
3/4 X 3	10.805	6.125
1 X 3	10.805	6.125
1 1/2 X 4	12.67	7
2 X 4	12.67	7
3 X 6	16.82	10.42
4 X 8	21.125	11.875
6 X 10	25.625	13.375
8 X 12	30.25	15.75
10 X 14	34.25	17.75
12 X 16	38.5	19.5

SCHEDULE 80 PVC X SCHEDULE 40 CLEAR
SCHEDULE 80 CPVC X SCHEDULE 40 CLEAR

PIPE SIZE	DIMENSIONS	
	A	B
1/2 X 2	8.97	5.125
3/4 X 2	8.97	5.125
3/4 X 3	10.805	6.125
1 X 3	10.805	6.125
1 1/2 X 4	12.67	7
2 X 4	12.67	7
3 X 6	16.82	10.42
4 X 8	N/A	N/A
6 X 10	N/A	N/A
8 X 12	N/A	N/A
10 X 14	N/A	N/A
12 X 16	N/A	N/A



FLO SAFE, INC.

CONTAINMENT FITTINGS

END SEAL

DATE 1/7/02	BY RL	DWG. NO. 00002011
-------------	-------	-------------------

FLO GUARD END SEAL


SCHEDULE 80 PVC X SCHEDULE 80 PVC
 SCHEDULE 80 CPVC X SCHEDULE 80 PVC
 SCHEDULE 80 CPVC X SCHEDULE 80 CPVC

**SCHEDULE 80 PVC X SCHEDULE 80 PVC
 SCHEDULE 80 CPVC X SCHEDULE 80 PVC**

PIPE SIZE	DIMENSIONS	
	A	B
1/2 X 2	8.125	5
3/4 X 2	8.125	5
3/4 X 3	10.063	6.063
1 X 3	10.063	6.063
1 1/2 X 4	11.25	6.875
2 X 4	11.25	6.875
3 X 6	15.313	9.063
4 X 8	20.031	11.594
6 X 10	26.5	13.5
8 X 12	30.625	15.125
10 X 14	33.844	16.844
12 X 16	38.375	19.125

SCHEDULE 80 CPVC X SCHEDULE 80 CPVC

PIPE SIZE	DIMENSIONS	
	A	B
1/2 X 2	8.125	5
3/4 X 2	8.125	5
3/4 X 3	10.063	6.063
1 X 3	10.063	6.063
1 1/2 X 4	11.25	6.875
2 X 4	11.25	6.875
3 X 6	15.313	9.063
4 X 8	20.031	11.594
6 X 10	26.5	13.5
8 X 12	30.625	15.125
10 X 14	N/A	N/A
12 X 16	N/A	N/A



FLO SAFE, INC.

CONTAINMENT FITTINGS

END SEAL

DATE	1/7/02	BY	RL	DWG. NO.	00002012
------	--------	----	----	----------	----------

FLO GUARD COMBINATION LATERAL WYE


SCHEDULE 40 PVC X SCHEDULE 40 PVC
 SCHEDULE 40 PVC X SCHEDULE 40 CLEAR
 SCHEDULE 40 CLEAR X SCHEDULE 40 CLEAR

SCHEDULE 40 PVC X SCHEDULE 40 PVC

PIPE SIZE	DIMENSIONS		
	A	B	C
2 X 4	26	22	21.75
3 X 6	30	24	26.06
4 X 8	34	26	25.125
6 X 10	38	28	31.469
8 X 12	42	30	35.25
10 X 14	44	32	38.25
12 X 16	48	34	41.875

**SCHEDULE 40 PVC X SCHEDULE 40 CLEAR
 SCHEDULE 40 CLEAR X SCHEDULE 40 CLEAR**

PIPE SIZE	DIMENSIONS		
	A	B	C
2 X 4	26	22	21.75
3 X 6	30	24	26.06
4 X 8	N/A	N/A	N/A
6 X 10	N/A	N/A	N/A
8 X 12	N/A	N/A	N/A
10 X 14	N/A	N/A	N/A
12 X 16	N/A	N/A	N/A



FLO SAFE, INC.

CONTAINMENT FITTINGS

COMBINATION LATERAL WYE

DATE	1/7/02	BY	RL	DWG. NO.	00002013
------	--------	----	----	----------	----------

FLO GUARD COMBINATION LATERAL WYE


SCHEDULE 80 PVC X SCHEDULE 40 PVC
 SCHEDULE 80 CPVC X SCHEDULE 40 PVC
 SCHEDULE 80 PVC X SCHEDULE 40 CLEAR
 SCHEDULE 80 CPVC X SCHEDULE 40 CLEAR

**SCHEDULE 80 PVC X SCHEDULE 40 PVC
 SCHEDULE 80 CPVC X SCHEDULE 40 PVC**

PIPE SIZE	DIMENSIONS		
	A	B	C
2 X 4	26	22	21.75
3 X 6	30	24	26.06
4 X 8	34	26	25.125
6 X 10	38	28	31.469
8 X 12	42	30	35.25
10 X 14	44	32	38.25
12 X 16	48	34	41.875

**SCHEDULE 80 PVC X SCHEDULE 40 CLEAR
 SCHEDULE 80 CPVC X SCHEDULE 40 CLEAR**

PIPE SIZE	DIMENSIONS		
	A	B	C
2 X 4	26	22	21.75
3 X 6	30	24	26.06
4 X 8	N/A	N/A	N/A
6 X 10	N/A	N/A	N/A
8 X 12	N/A	N/A	N/A
10 X 14	N/A	N/A	N/A
12 X 16	N/A	N/A	N/A



FLO SAFE, INC.

CONTAINMENT FITTINGS

COMBINATION LATERAL WYE

DATE	1/7/02	BY	RL	DWG. NO.	00002014
------	--------	----	----	----------	----------

FLO GUARD COMBINATION LATERAL WYE


SCHEDULE 80 PVC X SCHEDULE 80 PVC
 SCHEDULE 80 CPVC X SCHEDULE 80 PVC
 SCHEDULE 80 CPVC X SCHEDULE 80 CPVC

**SCHEDULE 80 PVC X SCHEDULE 80 PVC
 SCHEDULE 80 CPVC X SCHEDULE 80 PVC**

PIPE SIZE	DIMENSIONS		
	A	B	C
2 X 4	26	22	21.375
3 X 6	30	24	26.125
4 X 8	34	26	29.219
6 X 10	38	28	35.5
8 X 12	42	30	38.625
10 X 14	44	32	41.5
12 X 16	48	34	44.625

SCHEDULE 80 CPVC X SCHEDULE 80 CPVC

PIPE SIZE	DIMENSIONS		
	A	B	C
2 X 4	26	22	21.375
3 X 6	30	24	26.125
4 X 8	34	26	29.219
6 X 10	38	28	35.5
8 X 12	42	30	38.625
10 X 14	N/A	N/A	N/A
12 X 16	N/A	N/A	N/A



FLO SAFE, INC.

CONTAINMENT FITTINGS

COMBINATION LATERAL WYE

DATE	1/7/02	BY	RL	DWG. NO.	00002015
------	--------	----	----	----------	----------

FLO GUARD TEE

SCHEDULE 40 PVC X SCHEDULE 40 PVC
 SCHEDULE 40 PVC X SCHEDULE 40 CLEAR
 SCHEDULE 40 CLEAR X SCHEDULE 40 CLEAR


SCHEDULE 40 PVC X SCHEDULE 40 PVC

PIPE SIZE	DIMENSIONS			
	X	Y	Z	A
3 X 6	7.17	3.692	1.97	5.17
4 X 8	8.5	4.5	2.313	6.5
6 X 10	10.844	5.75	3.5	7.375
8 X 12	12.813	6.813	4.5	8.344
10 X 14	18	11.313	5.75	12.75
12 X 16	21	13	6.813	14.75

SCHEDULE 40 CLEAR X SCHEDULE 40 CLEAR

SCHEDULE 40 PVC X SCHEDULE 40 CLEAR

PIPE SIZE	DIMENSIONS			
	X	Y	Z	A
3 X 6	7.17	3.692	1.97	5.17
4 X 8	N/A	N/A	N/A	N/A
6 X 10	N/A	N/A	N/A	N/A
8 X 12	N/A	N/A	N/A	N/A
10 X 14	N/A	N/A	N/A	N/A
12 X 16	N/A	N/A	N/A	N/A



FLO SAFE, INC.

CONTAINMENT FITTINGS

TEE

DATE 1/7/02

BY RL

DWG. NO. 00002016

FLO GUARD TEE


SCHEDULE 80 PVC X SCHEDULE 40 PVC
 SCHEDULE 80 CPVC X SCHEDULE 40 PVC
 SCHEDULE 80 PVC X SCHEDULE 40 CLEAR
 SCHEDULE 80 CPVC X SCHEDULE 40 CLEAR

**SCHEDULE 80 PVC X SCHEDULE 40 PVC
 SCHEDULE 80 CPVC X SCHEDULE 40 PVC**

PIPE SIZE	DIMENSIONS			
	X	Y	Z	A
3 X 6	7.17	3.692	2.221	5.295
4 X 8	8.5	4.5	2.469	6.219
6 X 10	10.844	5.75	3.844	7.875
8 X 12	12.813	6.813	4.75	8.782
10 X 14	18	11.313	5.656	12.75
12 X 16	21	13	6.938	14.75

**SCHEDULE 80 PVC X SCHEDULE 40 CLEAR
 SCHEDULE 80 CPVC X SCHEDULE 40 CLEAR**

PIPE SIZE	DIMENSIONS			
	X	Y	Z	A
3 X 6	7.17	3.692	2.221	5.295
4 X 8	N/A	N/A	N/A	N/A
6 X 10	N/A	N/A	N/A	N/A
8 X 12	N/A	N/A	N/A	N/A
10 X 14	N/A	N/A	N/A	N/A
12 X 16	N/A	N/A	N/A	N/A



FLO SAFE, INC.

CONTAINMENT FITTINGS

TEE

DATE 1/7/02

BY RL

DWG. NO. 00002017

FLO GUARD TEE


SCHEDULE 80 PVC X SCHEDULE 80 PVC
 SCHEDULE 80 CPVC X SCHEDULE 80 PVC
 SCHEDULE 80 CPVC X SCHEDULE 80 CPVC

SCHEDULE 80 PVC X SCHEDULE 80 PVC
SCHEDULE 80 CPVC X SCHEDULE 80 PVC

PIPE SIZE	DIMENSIONS			
	X	Y	Z	A
3 X 6	7.409	4.603	2.219	5.219
4 X 8	8.781	4.813	2.469	6.5
6 X 10	10.813	5.75	4.063	7.844
8 X 12	12.813	6.75	4.813	8.782
10 X 14	18.5	11.5	5.656	13.25
12 X 16	20.5	12.5	6.938	14.25

SCHEDULE 80 CPVC X SCHEDULE 80 CPVC

PIPE SIZE	DIMENSIONS			
	X	Y	Z	A
3 X 6	7.409	4.603	2.219	5.219
4 X 8	8.781	4.813	2.469	6.5
6 X 10	10.813	5.75	4.063	7.844
8 X 12	12.813	6.75	4.813	8.782
10 X 14	N/A	N/A	N/A	N/A
12 X 16	N/A	N/A	N/A	N/A



FLO SAFE, INC.

CONTAINMENT FITTINGS

TEE


DATE 1/7/02

BY RL

DWG. NO. 00002018

FLO GUARD 90° ELBOW

SCHEDULE 40 PVC X SCHEDULE 40 PVC
 SCHEDULE 40 CLEAR X SCHEDULE 40 CLEAR
 SCHEDULE 40 PVC X SCHEDULE 40 CLEAR



SCHEDULE 40 PVC X SCHEDULE 40 PVC

PIPE SIZE	DIMENSIONS		
	X	Y	Z
3 X 6	7.27	3.785	1.99
4 X 8	8.813	4.375	2.281
6 X 10	10.688	5.688	3.438
8 X 12	12.719	6.688	4.375
10 X 14	23.25	16.25	5.688
12 X 16	26.563	18.563	6.688

SCHEDULE 40 CLEAR X SCHEDULE 40 CLEAR
SCHEDULE 40 PVC X SCHEDULE 40 CLEAR

PIPE SIZE	DIMENSIONS		
	X	Y	Z
3 X 6	7.27	3.785	1.99
4 X 8	N/A	N/A	N/A
6 X 10	N/A	N/A	N/A
8 X 12	N/A	N/A	N/A
10 X 14	N/A	N/A	N/A
12 X 16	N/A	N/A	N/A

FLO SAFE, INC.


CONTAINMENT FITTINGS

90° ELBOW

DATE	1/7/02	BY	RL	DWG. NO.	00002019
------	--------	----	----	----------	----------

FLO GUARD 90° ELBOW

SCHEDULE 80 PVC X SCHEDULE 40 PVC
 SCHEDULE 80 CPVC X SCHEDULE 40 PVC
 SCHEDULE 80 PVC X SCHEDULE 40 CLEAR
 SCHEDULE 80 CPVC X SCHEDULE 40 CLEAR



**SCHEDULE 80 PVC X SCHEDULE 40 PVC
 SCHEDULE 80 CPVC X SCHEDULE 40 PVC**

PIPE SIZE	DIMENSIONS		
	X	Y	Z
3 X 6	7.27	3.785	2.094
4 X 8	8.813	4.375	2.406
6 X 10	10.688	5.688	3.75
8 X 12	12.719	6.688	4.75
10 X 14	23.25	16.25	5.813
12 X 16	26.563	18.563	6.75

**SCHEDULE 80 PVC X SCHEDULE 40 CLEAR
 SCHEDULE 80 CPVC X SCHEDULE 40 CLEAR**

PIPE SIZE	DIMENSIONS		
	X	Y	Z
3 X 6	7.27	3.785	2.094
4 X 8	N/A	N/A	N/A
6 X 10	N/A	N/A	N/A
8 X 12	N/A	N/A	N/A
10 X 14	N/A	N/A	N/A
12 X 16	N/A	N/A	N/A

FLO SAFE, INC.


CONTAINMENT FITTINGS

90° ELBOW

DATE	1/7/02	BY	RL	DWG. NO.	00002020
------	--------	----	----	----------	----------

FLO GUARD 90° ELBOW

SCHEDULE 80 PVC X SCHEDULE 80 PVC
 SCHEDULE 80 CPVC X SCHEDULE 80 PVC
 SCHEDULE 80 CPVC X SCHEDULE 80 CPVC



**SCHEDULE 80 PVC X SCHEDULE 80 PVC
 SCHEDULE 80 CPVC X SCHEDULE 80 PVC**

PIPE SIZE	DIMENSIONS		
	X	Y	Z
3 X 6	6.875	3.75	2.094
4 X 8	8.75	4.75	2.406
6 X 10	11.375	5.813	3.5
8 X 12	13.375	6.75	4.75
10 X 14	23.875	16.875	5.813
12 X 16	26.875	18.875	6.75

SCHEDULE 80 CPVC X SCHEDULE 80 CPVC

PIPE SIZE	DIMENSIONS		
	X	Y	Z
3 X 6	6.875	3.75	2.094
4 X 8	8.75	4.75	2.406
6 X 10	11.375	5.813	3.5
8 X 12	13.375	6.75	4.75
10 X 14	N/A	N/A	N/A
12 X 16	N/A	N/A	N/A

FLO SAFE, INC.


CONTAINMENT FITTINGS

90° ELBOW

DATE	1/7/02	BY	RL	DWG. NO.	00002021
------	--------	----	----	----------	----------

FLO GUARD 90° ELBOW

SCHEDULE 40 PVC X SCHEDULE 40 PVC
 SCHEDULE 40 PVC X SCHEDULE 40 CLEAR
 SCHEDULE 40 CLEAR X SCHEDULE 40 CLEAR




PIPE SIZE	DIMENSIONS A
1/2 X 2	5.753
3/4 X 2	5.753
3/4 X 3	7.27
1 X 3	7.27
1 1/2 X 4	8.395
2 X 4	8.395

FLO SAFE, INC.		
CONTAINMENT FITTINGS		
90° ELBOW		
DATE	BY	DWG. NO.
1/7/02	RL	00002022

FLO GUARD 90° ELBOW

SCHEDULE 80 PVC X SCHEDULE 40 PVC
 SCHEDULE 80 CPVC X SCHEDULE 40 PVC
 SCHEDULE 80 CPVC X SCHEDULE 40 CLEAR
 SCHEDULE 80 PVC X SCHEDULE 40 CLEAR




PIPE SIZE	DIMENSIONS A
1/2 X 2	5.753
3/4 X 2	5.753
3/4 X 3	7.27
1 X 3	7.27
1 1/2 X 4	8.395
2 X 4	8.395

FLO SAFE, INC.		
CONTAINMENT FITTINGS		
90° ELBOW		
DATE	BY	DWG. NO.
1/7/02	RL	00002023

FLO GUARD 90° ELBOW

SCHEDULE 80 PVC X SCHEDULE 80 PVC
SCHEDULE 80 CPVC X SCHEDULE 80 PVC
SCHEDULE 80 CPVC X SCHEDULE 80 CPVC




PIPE SIZE	DIMENSIONS A
1/2 X 2	5.5
3/4 X 2	5.5
3/4 X 3	6.969
1 X 3	6.969
1 1/2 X 4	8.219
2 X 4	8.219

FLO SAFE, INC.		
CONTAINMENT FITTINGS		
90° ELBOW		
DATE	BY	DWG. NO.
1/7/02	RL	00002024

FLO GUARD 45° ELBOW

SCHEDULE 40 PVC X SCHEDULE 40 PVC
 SCHEDULE 40 PVC X SCHEDULE 40 CLEAR
 SCHEDULE 40 CLEAR X SCHEDULE 40 CLEAR




PIPE SIZE	DIMENSIONS A
1/2 X 2	5.273
3/4 X 2	5.273
3/4 X 3	7.41
1 X 3	7.41
1 1/2 X 4	8.625
2 X 4	8.625

FLO SAFE, INC.		
CONTAINMENT FITTINGS		
45° ELBOW		
DATE	BY	DWG. NO.
1/7/02	RL	00002025

FLO GUARD 45° ELBOW

SCHEDULE 80 PVC X SCHEDULE 40 PVC
 SCHEDULE 80 CPVC X SCHEDULE 40 PVC
 SCHEDULE 80 PVC X SCHEDULE 40 CLEAR
 SCHEDULE 80 CPVC X SCHEDULE 40 CLEAR




PIPE SIZE	DIMENSIONS A
1/2 X 2	5.273
3/4 X 2	5.273
3/4 X 3	7.41
1 X 3	7.41
1 1/2 X 4	8.625
2 X 4	8.625

FLO SAFE, INC.		
CONTAINMENT FITTINGS		
45° ELBOW		
DATE	BY	DWG. NO.
1/7/02	RL	00002026

FLO GUARD 45° ELBOW

SCHEDULE 80 PVC X SCHEDULE 80 PVC
 SCHEDULE 80 CPVC X SCHEDULE 80 PVC
 SCHEDULE 80 CPVC X SCHEDULE 80 CPVC




PIPE SIZE	DIMENSIONS A
1/2 X 2	4.75
3/4 X 2	4.75
3/4 X 3	5.875
1 X 3	5.875
1 1/2 X 4	6.781
2 X 4	6.781

FLO SAFE, INC.		
CONTAINMENT FITTINGS		
45° ELBOW		
DATE	BY	DWG. NO.
1/7/02	RL	00002027

FLO GUARD 45° ELBOW

SCHEDULE 40 PVC X SCHEDULE 40 PVC
 SCHEDULE 40 PVC X SCHEDULE 40 CLEAR
 SCHEDULE 40 CLEAR X SCHEDULE 40 CLEAR



SCHEDULE 40 PVC X SCHEDULE 40 PVC

PIPE SIZE	DIMENSIONS		
	X	Y	Z
3 X 6	5.8	1.61	1.062
4 X 8	6.813	2.344	1.25
6 X 10	8.594	3.063	2.031
8 X 12	10	3.563	2.344
10 X 14	12	4	3.063
12 X 16	13.375	5.375	3.563

SCHEDULE 40 PVC X SCHEDULE 40 CLEAR
SCHEDULE 40 CLEAR X SCHEDULE 40 CLEAR

PIPE SIZE	DIMENSIONS		
	X	Y	Z
3 X 6	5.8	1.61	1.062
4 X 8	N/A	N/A	N/A
6 X 10	N/A	N/A	N/A
8 X 12	N/A	N/A	N/A
10 X 14	N/A	N/A	N/A
12 X 16	N/A	N/A	N/A

FLO SAFE, INC.


CONTAINMENT FITTINGS

45° ELBOW

DATE	1/7/02	BY	RL	DWG. NO.	00002028
------	--------	----	----	----------	----------

FLO GUARD 45° ELBOW

SCHEDULE 80 PVC X SCHEDULE 40 PVC
 SCHEDULE 80 CPVC X SCHEDULE 40 PVC
 SCHEDULE 80 PVC X SCHEDULE 40 CLEAR
 SCHEDULE 80 CPVC X SCHEDULE 40 CLEAR



**SCHEDULE 80 PVC X SCHEDULE 40 PVC
 SCHEDULE 80 CPVC X SCHEDULE 40 PVC**

PIPE SIZE	DIMENSIONS		
	X	Y	Z
3 X 6	5.563	2.031	1
4 X 8	6.813	2.344	1.156
6 X 10	8.594	3.063	1.75
8 X 12	10	3.563	2.281
10 X 14	12	4	2.625
12 X 16	13.375	5.375	3.875

**SCHEDULE 80 PVC X SCHEDULE 40 CLEAR
 SCHEDULE 80 CPVC X SCHEDULE 40 CLEAR**

PIPE SIZE	DIMENSIONS		
	X	Y	Z
3 X 6	5.563	2.031	1
4 X 8	N/A	N/A	N/A
6 X 10	N/A	N/A	N/A
8 X 12	N/A	N/A	N/A
10 X 14	N/A	N/A	N/A
12 X 16	N/A	N/A	N/A

FLO SAFE, INC.


CONTAINMENT FITTINGS

45° ELBOW

DATE	1/7/02	BY	RL	DWG. NO.	00002029
------	--------	----	----	----------	----------

FLO GUARD 45° ELBOW

SCHEDULE 80 PVC X SCHEDULE 80 PVC
 SCHEDULE 80 CPVC X SCHEDULE 80 PVC
 SCHEDULE 80 CPVC X SCHEDULE 80 CPVC



**SCHEDULE 80 PVC X SCHEDULE 80 PVC
 SCHEDULE 80 PVC X SCHEDULE 80 CPVC**

PIPE SIZE	DIMENSIONS		
	X	Y	Z
3 X 6	4.75	1.75	1
4 X 8	6.313	2.281	1.156
6 X 10	8.25	2.625	1.75
8 X 12	10.438	3.875	2.281
10 X 14	12.25	5	2.625
12 X 16	13.563	5.563	3.875

SCHEDULE 80 CPVC X SCHEDULE 80 CPVC

PIPE SIZE	DIMENSIONS		
	X	Y	Z
3 X 6	4.75	1.75	1
4 X 8	6.313	2.281	1.156
6 X 10	8.25	2.625	1.75
8 X 12	10.438	3.875	2.281
10 X 14	N/A	N/A	N/A
12 X 16	N/A	N/A	N/A

FLO SAFE, INC.

CONTAINMENT FITTINGS

45° ELBOW

DATE	1/7/02	BY	RL	DWG. NO.	00002030
------	--------	----	----	----------	----------